



LTL NUMBER: 07220

DATE: 02-04-2003

PREPARED FOR: PRECISION ARCHITECTURAL LIGHTING

CATALOG NUMBER: TRPO2-PP4-4-PB-120-T8

LUMINAIRE: EXTRUDED ALUMINUM HOUSING, FORMED SPECULAR ALUMINUM REFLECTORS BESIDE LAMPS, 12 CELL, 1 1/2" DEEP, FORMED SEMI-SPECULAR ALUMINUM LOUVER BELOW LAMPS, CLEAR POLYCARBONATE ENCLOSURE WITH LAMINATED PERFORATED SPECULAR LAYER ABOVE LAMPS.

LAMPS: TWO PHILIPS F32T8/TL841 RATED AT 2850 LUMENS EACH.

BALLAST: ONE ADVANCE REL-2P32-SC

MOUNTING: WALL

LUMEN TO CANDELA RATIO USED = 9.18

TOTAL INPUT WATTS = 56.1 AT 120.0 VOLTS

THE 0 DEGREE PLANE IS PERPENDICULAR TO THE LAMPS.

CANDELA DISTRIBUTION										FLUX
	0.0	22.5	45.0	67.5	90.0	112.5	135.0	157.5	180.0	
0	889	889	889	889	889	889	889	889	889	
5	982	961	944	909	880	876	884	887	891	88
15	1178	1152	1077	943	838	858	929	969	970	277
25	1103	1105	1085	955	764	832	883	892	897	431
35	763	803	913	899	663	756	755	734	725	491
45	791	730	610	726	529	597	580	717	807	504
55	448	457	497	473	377	416	511	501	499	410
65	151	165	162	173	150	173	189	212	223	170
75	17	17	18	18	15	19	21	21	21	23
85	4	5	4	4	4	4	4	4	4	5
90	0	0	0	0	0	0	0	0	0	
95	10	13	15	13	10	13	13	12	13	15
105	97	109	121	104	63	96	99	85	85	102
115	300	313	290	207	155	207	267	269	271	245
125	455	435	372	290	248	297	362	416	438	319
135	492	468	406	374	328	369	411	457	475	319
145	483	475	462	444	394	427	465	491	497	286
155	512	513	512	487	445	469	493	512	519	228
165	547	543	529	497	477	493	508	515	519	145
175	517	508	504	495	493	497	506	507	502	48
180	497	497	497	497	497	497	497	497	497	

ZONAL LUMEN SUMMARY

ZONE	LUMENS	%LAMP	%FIXT
0- 30	796	14.0	19.4
0- 40	1286	22.6	31.3
0- 60	2200	38.6	53.6
0- 90	2398	42.1	58.4
90-120	362	6.4	8.8
90-130	681	11.9	16.6
90-150	1286	22.6	31.3
90-180	1707	29.9	41.6
0-180	4105	72.0	100.0

TOTAL LUMINAIRE EFFICIENCY: 72.0%


CIE TYPE: GENERAL DIFFUSE

PLANE: 0-DEG 90-DEG 180-DEG

SPACING CRITERIA: 1.4 1.2 1.3

SHIELDING ANGLES: 30 21 30

#07220



TESTED BY HERSCHEL SCHRECK
 CHECKED BY MIKE GRATHER



LTL NUMBER: 07220

DATE: 02-04-2003

PREPARED FOR: PRECISION ARCHITECTURAL LIGHTING


ZONAL LUMEN SUMMARY

0- 5	21.
5- 10	66.
10- 15	115.
15- 20	162.
20- 25	201.
25- 30	230.
30- 35	245.
35- 40	246.
40- 45	252.
45- 50	252.
50- 55	229.
55- 60	180.
60- 65	120.
65- 70	51.
70- 75	16.
75- 80	7.
80- 85	3.
85- 90	3.
90- 95	3.
95-100	12.
100-105	33.
105-110	69.
110-115	108.
115-120	138.
120-125	156.
125-130	162.
130-135	162.
135-140	157.
140-145	149.
145-150	138.
150-155	123.
155-160	105.
160-165	84.
165-170	61.
170-175	36.
175-180	12.

PLANE: 0-DEG 90-DEG
 LUMINOUS LENGTH: 4.000 48.000

LUMINANCE IN CANDELA PER SQUARE METER

ANGLE IN DEG	AVERAGE 0-DEG	AVERAGE 45-DEG	AVERAGE 90-DEG
0	7176.	7176.	7176.
45	9030.	6964.	6039.
55	6305.	6995.	5306.
65	2884.	3094.	2865.
75	530.	561.	468.
85	370.	370.	370.





LTL NUMBER: 07220

DATE: 02-04-2003

PREPARED FOR: PRECISION ARCHITECTURAL LIGHTING

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

EFFECTIVE FLOOR CAVITY REFLECTANCE 0.20

Table with columns for RC, RW, and various reflectance values (80, 70, 50, 30, 10, 0) and rows for different cavity heights (0-10).

NOTE: THE ZONAL CAVITY CALCULATION TECHNIQUE IS ACCURATE WHEN LUMINAIRES WITH SYMMETRIC CANDELA DISTRIBUTIONS ARE EMPLOYED AND WHEN THE LUMINAIRES ARE LOCATED SYMMETRICALLY THROUGHOUT THE ROOM. THIS UNIT HAS SPECIAL CHARACTERISTICS AND THEREFORE THESE COEFFICIENTS SHOULD BE USED WITH CAUTION.

THIS TEST WAS CONDUCTED USING RELATIVE PHOTOMETRY TECHNIQUES ACCORDING TO STANDARD IESNA PROCEDURES. THE USER MUST THEREFORE USE CAUTION IN THE FOLLOWING SITUATIONS: 1) THIS TEST WAS PERFORMED USING A SPECIFIC BALLAST/LAMP COMBINATION. EXTRAPOLATION OF THESE DATA FOR OTHER BALLAST/LAMP COMBINATIONS MAY PRODUCE ERRONEOUS RESULTS. 2) ACCORDING TO IESNA PROCEDURES, THE BALLAST(S) AND LAMP(S) ARE PRESUMED TO PRODUCE 100% OF RATED OUTPUT. AN APPROPRIATE BALLAST FACTOR MUST BE APPLIED TO THE LUMEN OUTPUT RATINGS AND LUMINOUS INTENSITY VALUES GIVEN. 3) THIS TEST WAS CONDUCTED IN A CONTROLLED LABORATORY ENVIRONMENT WHERE THE AMBIENT TEMPERATURE WAS HELD AT 25 C 1 C. FIELD PERFORMANCE MAY DIFFER PARTICULARLY IN REGARDS TO CHANGE IN LUMINOUS OUTPUT AS A RESULT OF DIFFERENCE IN AMBIENT TEMPERATURE AND METHOD OF MOUNTING THE LUMINAIRE.



LUMINAIRE TESTING LABORATORY, INC.



905 Harrison Street · Allentown, PA 18103 · (610) 770-1044 · Fax (610) 770-8912 · www.LuminaireTesting.com

INITIAL ILLUMINATION OF 50 FOOTCANDLES USING LTL TEST NUMBER 07220
 LUMINAIRE SUSPENSION LENGTH = 1.5
 WORKING PLANE HEIGHT = 2.50
 FLOOR REFLECTANCE = 20

ROOM HT		8				9				10				12			
CEIL RF		80		70		80		70		80		70		80		70	
WALL RF		70	50	50	30	70	50	50	30	70	50	50	30	70	50	50	30
WIDTH	LENGTH																
10.	10.	2	2	2	3	2	2	3	3	2	3	3	3	3	3	3	4
10.	15.	3	3	3	3	3	3	3	4	3	3	4	4	3	4	4	5
15.	20.	5	5	5	5	5	5	5	6	5	5	6	6	5	6	7	7
15.	30.	6	7	7	8	7	7	8	8	7	8	8	9	7	8	9	10
20.	20.	6	6	6	7	6	6	7	7	6	7	7	8	7	8	8	9
20.	30.	8	9	9	10	8	9	10	10	9	9	10	11	9	10	11	12
20.	40.	11	11	12	12	11	12	12	13	11	12	13	14	12	13	14	15
20.	60.	15	16	17	18	16	17	18	19	16	17	18	20	17	19	20	21
30.	30.	12	12	13	14	12	13	13	14	12	13	14	15	13	14	15	16
30.	40.	15	16	17	17	15	16	17	18	16	17	18	19	17	18	19	20
30.	50.	19	19	21	21	19	20	21	22	19	21	22	23	20	22	23	25
30.	60.	22	23	25	25	23	24	25	26	23	24	26	27	24	26	27	29
60.	60.	43	44	47	48	43	45	48	49	44	46	49	50	45	47	50	53
60.	80.	56	58	62	63	57	59	63	64	58	60	64	66	59	62	66	68
60.	100.	70	72	77	78	71	73	78	79	72	74	79	81	73	76	81	84
100.	100.	115	117	125	127	116	118	127	129	117	120	128	131	119	123	131	135

QUANTITY OF LUMINAIRES